



# Centrum stavebního inženýrství a.s.

Fire Technical Laboratory

AUTHORIZED  
BODY No. 212

NOTIFIED  
BODY No. 1390

## CLASSIFICATION OF REACTION TO FIRE IN ACCORDANCE WITH ČSN EN 13501-1+A1:2010

**Applicant:** CIUR a.s.  
Malé náměstí 142/3  
110 00 Praha 1  
Czech Republic

**Prepared by:** Centrum stavebního inženýrství a.s.  
Pražská 16  
102 00 Praha 10  
Czech Republic

**Product name:** *CLIMATIZER PLUS*  
*THERMOCELL 040*  
*FLOCO`MOBIL*  
*Dämmflocke / UniFloc*

**Classification  
report No.:** PK-15-061

**Issue number:** 1/2

**Date of issue:** 12<sup>th</sup> July 2015

This classification report consists of 4 pages and may only be used or reproduced in its entirety.

Address:  
PRAŽSKÁ 16, 102 00 PRAHA 10, Czech Republic, E mail: csias@csias.cz, <http://www.csias.cz>  
Reg. No. 45274860, VAT No. CZ45274860. The Company is registered in the Commercial Register  
administered by the Municipal Court of Prague (section B, inset 1595).  
Fire Technical Laboratory, E-mail: ptl@csias.cz  
Phone: +420 281 017 111, Fax: +420 281 017 455

## 1. DETAILS OF CLASSIFIED PRODUCT

### Description:

The product *CLIMATIZER PLUS / THERMOCELL 040 / FLOCO`MOBIL Dämmflocke / UniFloc* is fully described in the test reports in support of the classification listed in clause 2. *THERMOCELL 040 / FLOCO`MOBIL Dämmflocke / UniFloc* are alternate names of the tested product *CLIMATIZER PLUS*.

## 2. TEST REPORTS AND TEST RESULTS IN SUPPORT OF THIS CLASSIFICATION

### Test reports

Name of laboratory	Name of sponsor	Test report ref. no.	Test method
CSI a.s., Fire technical laboratory	CIUR a.s.	15144 – 1/3	ČSN EN ISO 11925-2
		15144 – 2/3	
		15144 – 3/3	ČSN EN 13823

### Measured values

Test method	Parameter	Number of test	Results	
			Continuous parameter mean (m)	Compliance parameters
ČSN EN ISO 11925-2 <sup>(1)</sup> exposition = 30 s	$F_s \leq 150$ mm ignition of the filter paper	6	yes	yes (B to D)
		6	no	no (d0)
ČSN EN ISO 11925-2 <sup>(2)</sup> exposition = 30 s	$F_s \leq 150$ mm ignition of the filter paper	6	yes	yes (B to D)
		6	no	no (d0)
ČSN EN 13823	$FIGRA_{0,2 MJ}$ (W/s)	3	3,4	$\leq 120$ (B)
	$LFS < edge$	3	yes	yes (B)
	$THR_{600 s}$ (MJ)	3	1,2	$\leq 7,5$ (B)
	$SMOGRA$ (m <sup>2</sup> /s <sup>2</sup> )	3	0,0	$\leq 30$ (s1)
	$TSP_{600 s}$ (m <sup>2</sup> )	3	16,8	$\leq 50$ (s1)
	flaming droplets / particles	3	no	no (d0)

(1): surface flame attack

(2): edge flame attack – exposed edge of insulation layer

## 3. CLASSIFICATION AND DIRECT FIELD OF APPLICATION

### Reference and direct field of application

This classification has been carried out in accordance with the clause 11.6, 11.9.2. and 11.10.1 of ČSN EN 13501-1+A1:2010.

**Classification**

The product *CLIMATIZER PLUS / THERMOCELL 040 / FLOCO`MOBIL Dämmflocke / UniFloc*, in relation to its reaction to fire behaviour is classified:

**B**

The additional classification in relation to smoke production is:

**s1**

The additional classification in relation to flaming droplets/particles is:

**d0**

The format of the reaction to fire classification for *CLIMATIZER PLUS / THERMOCELL 040 / FLOCO`MOBIL Dämmflocke / UniFloc* is:

Fire behaviour		Smoke production			Flaming droplets	
B	-	s	1	,	d	0

**Reaction to fire classification: B-s1, d0**

**Field of application**

This classification is also valid for the following product parameters:

- thickness of insulation: without limitation
- density of insulation: 35 – 70 kg/m<sup>3</sup>

This classification is valid for the following end use conditions:

- Insulation *CLIMATIZER PLUS / THERMOCELL 040 / FLOCO`MOBIL Dämmflocke / UniFloc* applied to close cavity
- cavity walls are composed of products of reaction to fire class A2-s1, d0 at least 12 mm thickness and density of 525 kg/m<sup>3</sup> or greater, or any product of reaction to fire class A1.

## 4. LIMITATIONS

### Restrictions

This classification report is valid until 12<sup>th</sup> July 2020, provided that the technical specifications of the product will not be changed.

### Warning

This document does not represent type approval or certification of the product.

Prepared:



Jiří Socha



Reviewed:



Vít Slaboch  
technical manager of laboratory